

Spill Summary Report for NRC Report #736901

Report Date: 9/14/2022

Report Time: 4:00 PM EDT

Region II Hotline Log Entry Information

Data ID: 38135
Date Of Report: 9/30/2004 **NRC #:** 736901 **State #:** 0407247 **ERNS #:** 131768
Material Type: Oil **Receiver:** GLENN
Material / Amount: OIL, MISC: TRANSFORMER / 30.8 GALLON(S)
Location: Street:
City: MT. PLEASANT
County: WESTCHESTER
State: NY
Latitude:
Longitude:
Source of Pollution: CON EDISON
Water Body: STORM DRAIN
State Or EPA Responded: RP
Initial EPA Action: Phone RP
Status:
URL:

Associated Action Reports

DataID: 0003960

Date: 9/30/2004	Time: 14:47 EST	
Duty Officer/Responder Name:	NRC Report #: 736901	Hotline Log DataID: 38135
Action Information		
Description:		
Follup-Up:		
Person Contacted		
Name: Paul Walsh Organization: Con Edison Phone #: 212-580-8383		

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802
GOVERNMENT USE ONLYGOVERNMENT USE ONLY***
Information released to a third party shall comply with any
applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 736901

INCIDENT DESCRIPTION

*Report taken by: CIV NYDIA RAWLS at 14:01 on 30-SEP-04
Incident Type: FIXED
Incident Cause: NATURAL PHENOMENON
Affected Area: STORM DRAIN
The incident occurred on 30-SEP-04 at 08:10 local time.
Affected Medium: WATER STORM DRAIN

REPORTING PARTY

Name: ANDREW MORRIS
Organization: CON EDISON
Address: 128 WEST END AVENUE
NEW YORK, NY 10023
CON EDISON called for the responsible party.
PRIMARY Phone: (212)5806763

INCIDENT LOCATION

County: WESTCHESTER

City: MT. PLEASANT **State:** NY
HEART SCRABBLE ROAD/CROSS ROAD IS ROSE HILL ROAD

RELEASED MATERIAL(S)

CHRIS Code: OTF **Official Material Name:** OIL, MISC: TRANSFORMER
Also Known As:
Qty Released: 30.8 GALLON(S) **Qty in Water:** 0 UNKNOWN AMOUNT

DESCRIPTION OF INCIDENT

CALLER STATED THAT A TREE FELL ON SOME WIRES DUE TO UNKNOWN CAUSES AND CAUSED A
TRANSFORMER TO RELEASE OIL ONTO THE GROUND AND INTO A STORM DRAIN.

SENSITIVE INFORMATION

INCIDENT DETAILS

Package: N/A
Building ID:
Type of Fixed Object: OTHER
Power Generating Facility: NO
Generating Capacity:
Type of Fuel:
NPDES:
NPDES Compliance: UNKNOWN

---WATER INFORMATION---

Body of Water: STORM DRAIN
Tributary of: UNKNOWN
Nearest River Mile Marker:
Water Supply Contaminated: NO

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN
INJURIES: NO Hospitalized: Empl/Crew: Passenger:
FATALITIES: NO Empl/Crew: Passenger: Occupant:
EVACUATIONS: NO Who Evacuated: Radius/Area:
Damages: NO

		Hours	Direction of
<u>Closure Type</u>	<u>Description of Closure</u>	<u>Closed</u>	<u>Closure</u>
Air:	N		
Road:	N		Major Art N
Waterway:	N		
Track:	N		

Passengers Transferred: UNKNOWN

Environmental Impact: UNKNOWN

Media Interest: NONE Community Impact due to Material: NO

REPORTING PARTY

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: ANDREW MORRIS
Organization: CON EDISON
Address: 128 WEST END AVENUE
 NEW YORK, NY 10023
PRIMARY Phone: (212)5806763
Type of Organization: PUBLIC UTILITY

REMEDIAL ACTIONS

CLEAN UP UNDERWAY, CONTRACTOR HAS BEEN HIRED
Release Secured: YES
Release Rate:
Estimated Release Duration:

WEATHER

Weather: RAINY, 70°F

ADDITIONAL AGENCIES NOTIFIED

Federal:
State/Local: DEC, WESTCHESTER DEPT OF HEALTH
State/Local On Scene:
State Agency Number: 0407247

NOTIFICATIONS BY NRC

ATSDR NJ ATTN: J. KOLAKOWSKI (PRIMARY)
30-SEP-04 14:07 (609)5887658
ATSDR NY (PRIMARY)
30-SEP-04 14:07 (212)6374307
U.S. EPA II (PRIMARY)
30-SEP-04 14:08 (732)3214370 GLENN
FEDERAL EMERGENCY MANAGEMENT AGENCY (PRIMARY)
30-SEP-04 15:07 (800)6347084 DUTY OFFICER
NATIONAL INFRASTRUCTURE COORD CNTR (PRIMARY)
30-SEP-04 15:07 (202)2829201 DUTY OFFICER
NOAA 1ST CLASS BB RPTS FOR NY (PRIMARY)
30-SEP-04 14:07 (206)5266344
BUREAU TOXIC SUBSTANCE R. WILBURN (PRIMARY)
30-SEP-04 14:07 (518)4027810

NY STATE DEC SPILL HOTLINE (PRIMARY)
30-SEP-04 14:07 (518)4577362
CTDEP OIL & CHEM SPILL RESP DIV (PRIMARY)
30-SEP-04 14:07 (860)4243338
NJ DEP POC: DUTY OFFICER (PRIMARY)
30-SEP-04 14:07 (609)5882848

ADDITIONAL INFORMATION

CALLER STATED THAT THE TRANSFORMER OIL IS NON PCB.

*** END INCIDENT REPORT # 736901 ***
Report any problems or Fax number changes by calling 1-800-424-8802
PLEASE VISIT OUR WEB SITE AT <http://www.nrc.uscg.mil>